

TABLE II (Non Regulated)

Detected Levels					
Parameters	Unit	Your Water	SDWR	MCLG	Source
Alkalinity	mg/l	35.23	NS	NS	Erosion of natural deposits, water treatment processes
Hardness	mg/l	47.38	NS	NS	Presence of mineral deposits most commonly calcium and magnesium
Iron	mg/l	<0.05	0.3	NS	Erosion of natural deposits
Manganese	mg/l	<0.01	0.05	NS	Erosion of natural deposits
pH	pH units	7.8	6.5 - 8.5	NS	Measurement of acid or base neutralizing capacities of water
Sodium	mg/l	33.9	NS	NS	Erosion of natural deposits, chemical use in water treatment
Sulfate	mg/l	64.6	250	NS	Erosion of natural deposits, decay or organic matter