

TABLE IV - TURBIDITY(a)

Parameters	Unit	MCL	Your Water	Average	Range	MCLG Violation	Source
Turbidity	NTU	95% of samples <0.30	99.93% <0.3 NTU	0.06	0.03 - 0.31	N	Soil runoff

(a) Turbidity is a measure of the cloudiness of the water. PWC monitors it because it is a good indicator of the effectiveness of PWC's filtration system.