

TABLE V - MICROBIOLOGICAL CONTAMINANTS

Parameters	PWC Surface Water Distribution				Source
	MCL	MCLG	MCL Violation	Your Water	
Total Coliform Bacteria	5% of monthly samples are positive	0	N	0.81%	Naturally present in the environment
Fecal Coliform or <u>E. coli</u>	A routine sample and repeat sample are total coliform positive, and one is also fecal coliform or <u>E. coli</u> positive	0	N	0.00%	Human and animal fecal waste