



NOTES:

1. FIRE HYDRANTS SHALL BE INSTALLED NO MORE THAN ONE FOOT WITHIN THE N.C. D.O.T. RIGHT-OF-WAY.
2. THE DISTANCE FROM THE WATER MAIN TO THE FIRE HYDRANT VARIES. THE CONTRACTORS BID PRICE FOR FIRE HYDRANT ASSEMBLIES SHALL INCLUDE THE COST FOR THE VARYING FIRE HYDRANT LEG LENGTH.
3. COSTS TO INSTALL THE FIRE HYDRANT TO GRADE SHALL BE PAID BY THE CONTRACTOR.

FIRE HYDRANT AND VALVE DETAIL

N.T.S.

HOKE COUNTY REGIONAL
 WATER SYSTEM DETAILS
 HOKE COUNTY, NORTH CAROLINA

FIRE HYDRANT DETAIL