



## TAPPING SLEEVE AND VALVE ASSEMBLY

N.T.S.

### NOTES

- 1) TAPPING SLEEVE SHALL BE STAINLESS STEEL WRAP-AROUND TYPE AS MANUFACTURED BY FORD, MUELLER, OR ROMAC.
  - 2) PLACE TAPPING VALVE ON 4" CONCRETE BLOCK. PLACE BLOCK ON 6" COMPACTED #57 STONE. BACKFILL AROUND SLEEVE AND VALVE WITH STONE TO TOP OF PIPE.
- FULL CIRCLE SS BODY AS MANUFACTURED BY SMITH/BLAIR OR ROMAC

HOKE COUNTY REGIONAL  
WATER SYSTEM DETAILS  
HOKE COUNTY, NORTH CAROLINA

TAPPING SLEEVE AND VALVE  
ASSEMBLY