



**COMPLETE BOX**

**DIMENSIONS IN INCHES  
LENGTH**

TOP	BOTTOM
10	15
10	24
16	24
16	36
26	36
26	48
26	60

**NOTES:**

1. VALVE BOX SHALL HAVE RAISED LETTERS "SEWER" CAST INTO COVER.
2. VALVE BOX ACCOMMODATES 4" THRU 12" VALVES.
3. VALVE BOX SHALL HAVE 3/8" HOLE DRILLED IN TOP SECTION THRU WHICH A 1/4" X 1 1/2" GALVANIZED BOLT SHALL BE USED TO SECURE A 12GA. THHN TRACER WIRE FOR NON-FERROUS PIPE. A 1/2" WASHER SHALL BE USED BETWEEN NUT AND INSIDE OF BOX. TIGHTEN HAND TIGHT.
4. SCREW TYPE VALVE BOXES ARE REQUIRED.
5. DIMENSIONS SHOWN MAY VARY DEPENDING UPON THE MANUFACTURER.

**TOP SECTION**

**VALVE BOX DETAIL**

NTS

HOKE COUNTY REGIONAL  
SEWER SYSTEM DETAILS  
HOKE COUNTY, NORTH CAROLINA

VALVE BOX DETAIL