



NOTES:

1. THRUST BLOCKS SHALL BE CONSTRUCTED OF 2500 P.S.I. CONCRETE.
2. INSTALL TAR PAPER AROUND BEND OR FITTING TO PREVENT BONDING OF CONCRETE.

BEND / FITTING	DIMENSION A (FEET)								
	PIPE SIZE (NOM. DIA. IN INCHES)								
	4	6	8	10	12	16	18	20	24
90° BEND	1.4	2.0	2.7	3.4	4.0	5.4	6.0	6.7	8.0
45° BEND	1.0	1.5	2.0	2.5	3.0	4.0	4.5	5.0	5.9
22 1/2° BEND	0.8	1.1	1.5	1.8	2.2	2.9	3.2	3.6	4.3
11 1/4° BEND	0.5	0.8	1.0	1.3	1.5	2.0	2.3	2.5	3.0
TEE BRANCH/DEAD END	1.2	1.7	2.3	2.9	3.4	4.5	5.1	5.7	6.8

CONCRETE THRUST BLOCK DETAIL FOR HORIZONTAL BENDS AND TEES

N.T.S.

HOKE COUNTY REGIONAL
SEWER SYSTEM DETAILS
HOKE COUNTY, NORTH CAROLINA

CONCRETE THRUST BLOCK DETAIL
FOR HORIZONTAL BENDS AND TEES