



COUNTY OF HOKE

Public Works

DENNIS BAXLEY, DIRECTOR
POST OFFICE BOX 240
423 E. CENTRAL AVE.
RAEFORD, NORTH CAROLINA 28376
(910) 875-6704

NOTICE

In order to receive water and/or sewer allocations the following procedures should be followed.

- 1- Submit a request for water and/or sewer allocation to the Public Works Department. The request should list the amount of allocation needed and include a site map and build-out schedule for the project. Prior to review by the utility committee, a fire flow test will be performed at a hydrant closest to the proposed development (Hoke County does not perform flow test). The flow test should be scheduled with the department in advance so a department representative can be present. The request and fire flow results will be reviewed by the Utility Committee at the next available meeting and a recommendation will be sent to the Board of Commissioners for their consideration.
 - 2- If you are requesting a waiver of the sanitary sewer requirements of the Urban Services Area, a feasibility study should also be sent with the allocation request.
 - 3- Per the **DENR-PWS mandate**, the water demand for the development will have to be entered into the system water model (at the developer's expense). Data will be generated and a letter issued stating whether or not the water system has available capacity to meet domestic and fire flow requirements.
 - 4- Facility investment Fees are required to be paid prior to recording the final plat.
 - 5- The developer is required to furnish well lot(s) capable of producing a yield of 1 gallon per minutes per connection. If this yield can't be met the developer will be required to make a payment in lieu of well dedication (400gpd x number of connections x .70). This payment is made prior to recording the final plat.
 - 6- Hoke County has to perform annual asset inventories. The developer or his engineer shall submit to the Public Works Department the actual cost for water and sewer infrastructure prior to owner certification.
 - 7- As-builts shall be furnished as soon as possible after final approval has been received (2 hard copies, 1 digital copy) and prior to owner certification.
- The Public Works Rules and Regulations can be viewed on the Hoke County website.
 - Developers are encouraged to request fire flow tests prior to submitting their request for allocations. Doing so may head off any unnecessary delays or expenses.

